



**ONE-TIME COMPLIANCE REPORT FOR DENTAL DISCHARGERS
to Comply with 40 CFR 441.50
Effluent Guidelines and Standards for the Dental Office Category**

Name of Facility:					
Physical Address of Dental Facility:					
City:		State:		Zip:	
Mailing Address:					
City:		State:		Zip:	
Facility Contact:					
Phone:		Email:			
Names of Owner(s):					
Names of Operator(s) if different from Owner(s):					

Applicability: Please Select One of the Following

<input type="checkbox"/>	<p>This facility is a dental discharger subject to this rule (40 CFR Part 441) and it places or removes dental amalgam. <i>Complete sections A, B, C, D, and E</i></p>
<input type="checkbox"/>	<p>This facility is a dental discharger subject to this rule and (1) it does not place dental amalgam, and (2) it does not remove amalgam except in limited emergency or unplanned, unanticipated circumstances. <i>Complete section E only</i></p>
<p>(Also, select if applicable) Transfer of Ownership (§ 441.50(a)(4))</p>	
<input type="checkbox"/>	<p>This facility is a dental discharger subject to this rule (40 CFR Part 441), and it has previously submitted a one-time compliance report. This facility is submitting a new One Time Compliance Report because of a transfer of ownership as required by § 441.50(a)(4)</p>

Section A - Description of Facility

Total number of chairs:		
Total number of chairs at which amalgam may be present in the resulting wastewater (i.e., chairs where amalgam may be placed or removed):		
Description of any amalgam separator(s) or equivalent device(s) currently operated:		
YES <input type="checkbox"/>	NO <input type="checkbox"/>	The facility discharged amalgam process wastewater prior to July 14th, 2017 under any ownership.

Section B - Description of Amalgam Separator or Equivalent Device

<input type="checkbox"/>	The dental facility has installed one or more ISO 11143 (or ANSI/ADA 108-2009) compliant amalgam separators (or equivalent devices) that captures all amalgam containing waste at the following number of chairs at which amalgam placement or removal may occur:	Chairs:	
<input type="checkbox"/>	The dental facility installed prior to June 14, 2017 one or more existing amalgam separators that do not meet the requirements of § 441.30(a)(1)(i) and (ii) at the following number of chairs at which amalgam placement or removal may occur:	Chairs:	
<input type="checkbox"/>	I understand that such separators must be replaced with one or more amalgam separators (or equivalent devices) that meet the requirements of § 441.30(a)(1) or § 441.30(a)(2) , after their useful life has ended, and no later than June 14, 2027, whichever is sooner.		
	Make:	Model:	
		Year of installation:	
<input type="checkbox"/> My facility operates an equivalent device.			
	Make:	Model:	Year of installation:
			Average removal efficiency of equivalent device, as determined per § 441.30(a)(2)i- iii.

Section C - Design, Operation and Maintenance of Amalgam Separator/Equivalent Device

<input type="checkbox"/>	YES	I certify that the amalgam separator (or equivalent device) is designed and will be operated and maintained to meet the requirements in §441.30 or § 441.40 .	
A third-party service provider is under contract with this facility to ensure proper operation and maintenance in accordance with § 441.30 or § 441.40 .			
<input type="checkbox"/>	YES	Name of third-party service provider (e.g. Company Name) that maintains the amalgam separator or equivalent device (if applicable);	
<input type="checkbox"/>	NO	If none, provide a description of the practices employed by the facility to ensure proper operation and maintenance in accordance with § 441.30 or § 441.40 .	
Describe Practices:			

Section D - Best Management Practices (BMP) Certifications

<input type="checkbox"/>	<p>The above named dental discharger is implementing the following BMPs as specified in § 441.30(b) or § 441.40 and will continue to do so.</p> <ul style="list-style-type: none"> ● Waste amalgam including, but not limited to, dental amalgam from chair-side traps, screens, vacuum pump filters, dental tools, cuspidors, or collection devices, must not be discharged to a publicly owned treatment works (e.g., municipal sewage system). ● Dental unit water lines, chair-side traps, and vacuum lines that discharge amalgam process wastewater to a publicly owned treatment works (e.g., municipal sewage system) must not be cleaned with oxidizing or acidic cleaners, including but not limited to bleach, chlorine, iodine and peroxide that have a pH lower than 6 or greater than 8 (i.e. cleaners that may increase the dissolution of mercury).
--------------------------	---

Section E - Certification Statement

Per [§ 441.50\(a\)\(2\)](#), the One-Time Compliance Report must be signed and certified by a responsible corporate officer, a general partner or proprietor if the dental facility is a partnership or sole proprietorship, or a duly authorized representative in accordance with the requirements of [§ 403.12\(l\)](#).

"I am a responsible corporate officer, a general partner or proprietor (if the facility is a partnership or sole proprietorship), or a duly authorized representative in accordance with the requirements of § 403.12(l) of the above named dental facility, and certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Authorized Representative Name (print name):	
Phone:	Email:
Authorized Representative Signature:	Date:

Retention Period per [§ 441.50\(a\)\(5\)](#)

As long as a Dental facility subject to this part is in operation, or until ownership is transferred, the Dental facility or an agent or representative of the dental facility must maintain this One Time Compliance Report and make it available for inspection in either physical or electronic form.

PART 441—DENTAL OFFICE POINT SOURCE CATEGORY

Contents:

[§441.10 Applicability.](#)

[§441.20 General definitions.](#)

[§441.30 Pretreatment standards for existing sources \(PSES\).](#)

[§441.40 Pretreatment standards for new sources \(PSNS\).](#)

[§441.50 Reporting and recordkeeping requirements.](#)

§441.10 Applicability.

(a) Except as provided in paragraphs (c), (d), and (e) of this section, this part applies to dental dischargers.

(b) Unless otherwise designated by the Control Authority, dental dischargers subject to this part are not Significant Industrial Users as defined in 40 CFR part 403, and are not “Categorical Industrial Users” or “industrial users subject to categorical pretreatment standards” as those terms and variations are used in 40 CFR part 403, as a result of applicability of this rule.

(c) This part does not apply to dental dischargers that exclusively practice one or more of the following dental specialties: Oral pathology, oral and maxillofacial radiology, oral and maxillofacial surgery, orthodontics, periodontics, or prosthodontics.

(d) This part does not apply to wastewater discharges from a mobile unit operated by a dental discharger.

(e) This part does not apply to dental dischargers that do not discharge any amalgam process wastewater to a POTW, such as dental dischargers that collect all dental amalgam process wastewater for transfer to a Centralized Waste Treatment facility as defined in 40 CFR part 437.

(f) Dental Dischargers that do not place dental amalgam, and do not remove amalgam except in limited emergency or unplanned, unanticipated circumstances, and that certify such to the Control Authority as required in §441.50 are exempt from any further requirements of this part.

§441.20 General definitions.

For purposes of this part:

(a) *Amalgam process wastewater* means any wastewater generated and discharged by a dental discharger through the practice of dentistry that may contain dental amalgam.

(b) *Amalgam separator* means a collection device designed to capture and remove dental amalgam from the amalgam process wastewater of a dental facility.

(c) *Control Authority* is defined in 40 CFR 403.3(f).

(d) *Dental amalgam* means an alloy of elemental mercury and other metal(s) that is used in the practice of dentistry.

(e) *Dental Discharger* means a facility where the practice of dentistry is performed, including, but not limited to, institutions, permanent or temporary offices, clinics, home offices, and facilities owned and operated by Federal, state or local governments, that discharges wastewater to a publicly owned treatment works (POTW).

(f) *Duly Authorized Representative* is defined in 40 CFR 403.12(l)(3).

(g) *Existing Sources* means a dental discharger that is not a new source.

(h) *Mobile unit* means a specialized mobile self-contained van, trailer, or equipment used in providing dentistry services at multiple locations.

(i) *New Sources* means a dental discharger whose first discharge to a POTW occurs after July 14, 2017.

(j) *Publicly Owned Treatment Works* is defined in 40 CFR 403.3(q).

§441.30 Pretreatment standards for existing sources (PSES).

No later than July 14, 2020, any existing source subject to this part must achieve the following pretreatment standards:

(a) Removal of dental amalgam solids from all amalgam process wastewater by one of the following methods:

(1) Installation, operation, and maintenance of one or more amalgam separators that meet the following requirements:

operation and maintenance; including confirmation that amalgam process wastewater is flowing through the amalgam separating portion of the device(s).

(vi) In the event that a device is not functioning properly, it must be repaired consistent with manufacturer instructions or replaced with a unit that meets the requirements of paragraphs (a)(2)(i) through (iii) of this section as soon as possible, but no later than 10 business days after the malfunction is discovered by the dental discharger, or an agent or representative of the dental discharger.

(vii) The amalgam retaining unit(s) of the device(s) must be replaced as specified in the manufacturer's operating manual, or when the collecting container has reached the maximum filling level, as specified by the manufacturer in the operating manual, at which the amalgam separator can perform to the specified efficiency, whichever comes first.

(viii) The demonstration of the device(s) under paragraphs (a)(2)(i) through (iii) of this section must be documented in the One-Time Compliance Report.

(b) Implementation of the following best management practices (BMPs):

(1) Waste amalgam including, but not limited to, dental amalgam from chair-side traps, screens, vacuum pump filters, dental tools, cuspidors, or collection devices, must not be discharged to a POTW.

(2) Dental unit water lines, chair-side traps, and vacuum lines that discharge amalgam process wastewater to a POTW must not be cleaned with oxidizing or acidic cleaners, including but not limited to bleach, chlorine, iodine and peroxide that have a pH lower than 6 or greater than 8.

(c) All material is available for inspection at EPA's Water Docket, EPA West, 1301 Constitution Avenue NW., Room 3334, Washington, DC 20004, Telephone: 202-566-2426, and is available from the sources listed below.

(1) The following standards are available from the American Dental Association (ADA), 211 East Chicago Ave., Chicago IL 60611-2678, Telephone 312-440-2500, <http://www.ada.org>.

(i) ANSI/ADA Specification No. 108:2009, American National Standard/American Dental Association Specification No. 108 Amalgam Separators. February 2009.

(ii) ANSI/ADA Specification No. 108:2009 Addendum, American National Standard/American Dental Association Specification No. 108 Amalgam Separators, Addendum. November 2011.

(2) The following standards are available from the American National Standards Institute (ANSI), 25 West 43rd Street, 4th Floor, New York, NY 10036, Telephone 212-642-4900, <http://webstore.ansi.org>.

(i) International Standard ISO 11143:2008, Dentistry—Amalgam Separators. Second edition, July 1, 2008.

(ii) [Reserved]

[82 FR 27176, June 14, 2017; 82 FR 28777, June 26, 2017; 82 FR 30997, July 5, 2017]

§441.40 Pretreatment standards for new sources (PSNS).

As of July 14, 2017, any new source subject to this part must comply with the requirements of §441.30(a) and (b) and the reporting and recordkeeping requirements of §441.50.

§441.50 Reporting and recordkeeping requirements.

(a) Dental Dischargers subject to this part must comply with the following reporting requirements in lieu of the otherwise applicable requirements in 40 CFR 403.12(b), (d), (e), and (g).

(1) *One-Time Compliance Report deadlines.* For existing sources, a One-Time Compliance Report must be submitted to the Control Authority no later than October 12, 2020, or 90 days after a transfer of ownership. For new sources, a One-Time Compliance Report must be submitted to the Control Authority no later than 90 days following the introduction of wastewater into a POTW.

(2) *Signature and certification.* The One-Time Compliance Report must be signed and certified by a responsible corporate officer, a general partner or proprietor if the dental discharger is a partnership or

sole proprietorship, or a duly authorized representative in accordance with the requirements of 40 CFR 403.12(l).

(3) *Contents.* (i) The One-Time Compliance Report for dental dischargers subject to this part that do not place or remove dental amalgam as described at §441.10(f) must include the: facility name, physical address, mailing address, contact information, name of the operator(s) and owner(s); and a certification statement that the dental discharger does not place dental amalgam and does not remove amalgam except in limited circumstances.

(ii) The One-Time Compliance Report for dental dischargers subject to the standards of this part must include:

(A) The facility name, physical address, mailing address, and contact information.

(B) Name(s) of the operator(s) and owner(s).

(C) A description of the operation at the dental facility including: The total number of chairs, the total number of chairs at which dental amalgam may be present in the resulting wastewater, and a description of any existing amalgam separator(s) or equivalent device(s) currently operated to include, at a minimum, the make, model, year of installation.

(D) Certification that the amalgam separator(s) or equivalent device is designed and will be operated and maintained to meet the requirements specified in §441.30 or §441.40.

(E) Certification that the dental discharger is implementing BMPs specified in §441.30(b) or §441.40(b) and will continue to do so.

(F) The name of the third-party service provider that maintains the amalgam separator(s) or equivalent device(s) operated at the dental office, if applicable. Otherwise, a brief description of the practices employed by the facility to ensure proper operation and maintenance in accordance with §441.30 or §441.40.

(4) *Transfer of ownership notification.* If a dental discharger transfers ownership of the facility, the new owner must submit a new One-Time Compliance Report

to the Control Authority no later than 90 days after the transfer.

(5) *Retention period.* As long as a Dental Discharger subject to this part is in operation, or until ownership is transferred, the Dental Discharger or an agent or representative of the dental discharger must maintain the One-Time Compliance Report required at paragraph (a) of this section and make it available for inspection in either physical or electronic form.

(b) Dental Dischargers or an agent or representative of the dental discharger must maintain and make available for inspection in either physical or electronic form, for a minimum of three years:

(1) Documentation of the date, person(s) conducting the inspection, and results of each inspection of the amalgam separator(s) or equivalent device(s), and a summary of follow-up actions, if needed.

(2) Documentation of amalgam retaining container or equivalent container replacement (including the date, as applicable).

(3) Documentation of all dates that collected dental amalgam is picked up or shipped for proper disposal in accordance with 40 CFR 261.5(g)(3), and the name of the permitted or licensed treatment, storage or disposal facility receiving the amalgam retaining containers.

(4) Documentation of any repair or replacement of an amalgam separator or equivalent device, including the date, person(s) making the repair or replacement, and a description of the repair or replacement (including make and model).

(5) Dischargers or an agent or representative of the dental discharger must maintain and make available for inspection in either physical or electronic form the manufacturers operating manual for the current device.